

REPORT OF 031121

1. [Introduction](#)
2. [Summary](#)
 - [Instrument Unavailability](#)
 - [Browse Visual Inspection](#)
 - [Module Stepping Results](#)
 - [Data Analysis](#)
3. [Module Stepping](#)
4. [Internal Calibration pulses](#)
 - [Daily statistics \(row 3 and 24\)](#)
 - [Cyclic statistics \(row 3 and 24\)](#)
 - [cal pulses monitoring \(all rows\)](#)
5. [Raw Data Statistics](#)
 - [raw data mean I and Q](#)
 - [raw data stdev I and Q](#)
 - [raw gain imbalance](#)
6. [Wave Doppler analysis](#)
 - [Unbiased Doppler Error](#)
 - [Absolute Doppler](#)
 - [Doppler evolution versus ANX](#)

1 - Introduction

This report is based on the analysis of wave mode level-1 cross spectra (ASA_WVS_1P) products, which are the available few hours after the acquisition, on the high rate browse (BP) products and on the Module Stepping (MS) product.

2 - Summary

2.1 - Instrument Unavailability

ASAR unavailable from 21-NOV-2003 01:58:28 to 21-NOV-2003 10:42:00.

2.2 - Browse Visual Inspection

No anomalies observed on available browse products.

2.3 - Data Analysis

- Stable wave internal calibration pulses gain and phase.
- Stable raw data statistics.

-Nominal Doppler behavior.

3 - Module Stepping Mode

The MS mode provides an internal health check on an individual module basis. The purpose of this mode is to identify any malfunctioning modules and to identify modules for which calibration offsets are to be applied.

No anomalies observed on available MS products:

- ASA_MS__0PNPDK20031120_203059_000000152021_00443_09014_0027.N1
- ASA_MS__0PNPDK20031120_203219_000000152021_00443_09014_0028.N1

Polarisation	Start Time
V	20031120 203219
H	20031120 203059

MSM in V/V polarisation

Pre-launch Reference	DDS-B (2003-06-12) reference
☒	☒
☒	☒
☒	☒
☒	☒

MSM in H/H polarisation

Pre-launch Reference	DDS-B (2003-06-12) reference
☒	☒
☒	☒
☒	☒
☒	☒

4 - Internal calibration Results

No anomalies observed.

4.1 - Daily statistics

row	stat	AveP1	AveP2	AveP3
-----	------	-------	-------	-------

3	mean	-3.76525	-22.6159	-8.17844
	stdev	0.00760843	0.0641840	0.00345231
24	mean	-5.11726	-21.2805	-8.17844
	stdev	0.0141381	0.0538788	0.00345231



4.2 - Cyclic statistics

row	stat	AveP1	AveP2	AveP3
3	mean	-3.77658	-22.5559	-8.15672
	stdev	0.00604771	0.0658330	0.00311855
24	mean	-5.32589	-21.2466	-8.15672
	stdev	0.913800	0.0600604	0.00311855



4.3 - cal pulses monitoring (all rows)



5 - RAW data statistics

No anomalies observed.

5.1 - Input mean I/Q

channel	stat	DSS-B
MEAN I	mean	0.000329259
	stdev	1.00483e-05
MEAN Q	mean	0.000159550
	stdev	1.00347e-05



5.2 - Input stdev I/Q

channel	stat	DSS-B
---------	------	-------

STDEV I	mean	0.112716
	stdev	0.00154147
STDEV Q	mean	0.112964
	stdev	0.00155836



5.3 - Gain imbalance I/Q



6 - Wave Doppler Analysis

No anomalies observed in Doppler evolution.
Doppler analysis performed over the last 35 days.

6.1 - Unbiased Doppler Error




Evolution of unbiased Doppler error (Real - Expected)
Ascending
Descending

6.2 - Absolute Doppler


Evolution of Absolute Doppler
Ascending
Descending

6.3 - Doppler evolution versus ANX

Evolution Doppler error versus ANX





Average P1 (row 3 & row 24)




20-Nov

Average P2



20-Nov


Average P3



20-Nov

No anomalies observed on available browse products.


No anomalies observed.




- Stable wave internal calibration pulses gain and phase.
- Stable raw data statistics.
- Nominal Doppler behavior.



No anomalies observed in Doppler evolution.
Doppler analysis performed over the last 35 days.

Doppler 'WVS' 'IS2' 'H/H'




Doppler 'WVS' 'IS2' 'V/V'






Doppler difference, estimated-predicted 'WVS' 'IS2' 'H/H' -error mean of -95.089606 Hz



Doppler difference, estimated-predicted 'WVS' 'IS2' 'V/V' -error mean of -90.180213 Hz




The MS mode provides an internal health check on an individual module basis.
The purpose of this mode is to identify any malfunctioning modules and
to identify modules for which calibration offsets are to be applied.


No anomalies observed on available MS products:




- ASA_MS__0PNPDK20031120_203059_000000152021_00443_09014_0027.N1
- ASA_MS__0PNPDK20031120_203219_000000152021_00443_09014_0028.N1




No anomalies observed.

Reference: 2003-06-12 14:08:52 H RxGain
 Test : 2003-11-20 20:30:59 H









ASAR unavailable from 21-NOV-2003 01:58:28 to 21-NOV-2003 10:42:00.

