

REPORT OF 040320

last update on Mon Mar 22 15:42:21 GMT 2004

1. [Introduction](#)
2. [Summary](#)
 - [Instrument Unavailability](#)
 - [Browse Visual Inspection](#)
 - [Module Stepping Results](#)
 - [Data Analysis](#)
3. [Module Stepping](#)
4. [Internal Calibration pulses](#)
 - [Daily statistics](#)
 - [Cyclic statistics](#)
 - [cal pulses monitoring \(all rows\)](#)
5. [Raw Data Statistics](#)
 - [raw data mean I and Q](#)
 - [raw data stdev I and Q](#)
 - [raw gain imbalance](#)
6. [Wave Doppler analysis](#)
 - [Unbiased Doppler Error](#)
 - [Absolute Doppler](#)
 - [Doppler evolution versus ANX](#)

1 - Introduction

This report is based on the analysis of wave mode level-1 cross spectra (ASA_WVS_1P) products, which are the available few hours after the acquisition, on the high rate browse (BP) products and on the Module Stepping (MS) product.

2 - Summary

2.1 - Instrument Unavailability

Instrument unavailability from 19-MAR-2003 12:03:47 to 15:00:30

2.2 - Browse Visual Inspection

No anomaly detected on visual inspection.

2.3 - Data Analysis

- Stable wave internal calibration pulses gain and phase.
- Stable raw data statistics.
- Nominal Doppler behavior.

3 - Module Stepping Mode

The MS mode provides an internal health check on an individual module basis. The purpose of this mode is to identify any malfunctioning modules and to identify modules for which calibration offsets are to be applied.

No anomalies observed on available MS products:

Polarisation	Start Time
V	20040319 191350
H	20040319 191230

MSM in V/V polarisation

Pre-launch Reference	DDS-B (2003-06-12) reference
⊗	⊗
⊗	⊗
⊗	⊗
⊗	⊗

MSM in H/H polarisation

Pre-launch Reference	DDS-B (2003-06-12) reference
⊗	⊗
⊗	⊗
⊗	⊗
⊗	⊗

4 - Internal calibration Results

No anomalies observed.

4.1 - Daily statistics

⊗

4.2 - Cyclic statistics



P1 Cyclic statistics

row	pulse	mean (dB)	stdev (dB)	slope(dB/cycle)
3	P1	-3.614445	0.005969	0.048790
7	P1	-3.323998	0.010427	0.058664
11	P1	-4.795962	0.265057	0.490973
15	P1	-5.003971	0.040318	-0.016482
19	P1	-3.347167	0.073395	-0.065030
22	P1	-4.545870	0.070902	-0.064060
24	P1	-5.105628	0.091268	-0.023357
28	P1	-4.575544	0.076837	-0.092491

P2 Cyclic statistics

row	pulse	mean (dB)	stdev (dB)	slope(dB/cycle)
3	P2	-22.382696	0.081634	-0.026751
7	P2	-22.900803	0.129097	-0.014232
11	P2	-16.031542	0.158714	0.039619
15	P2	-7.179343	0.090206	0.019644
19	P2	-9.479440	0.167713	0.003638
22	P2	-17.680738	0.103400	0.051247
24	P2	-21.037176	0.113906	-0.038034
28	P2	-16.596392	0.087255	-0.000977

P3 Cyclic statistics

row	pulse	mean (dB)	stdev (dB)	slope(dB/cycle)
3	P3	-8.128279	0.002994	0.007485
7	P3	-8.128277	0.002994	0.007447
11	P3	-8.128271	0.002995	0.007399
15	P3	-8.128272	0.002995	0.007395
19	P3	-8.128279	0.002994	0.007440
22	P3	-8.128289	0.002994	0.007507
24	P3	-8.128299	0.002994	0.007582

4.3 - cal pulses monitoring (all rows)



5 - RAW data statistics

No anomalies observed.

5.1 - Input mean I/Q

channel	stat	DSS-B
MEAN I	mean	0.000471245
	stdev	2.34856e-07
MEAN Q	mean	0.000493675
	stdev	2.60106e-07



5.2 - Input stdev I/Q

channel	stat	DSS-B
STDEV I	mean	0.127440
	stdev	0.00112118
STDEV Q	mean	0.127673
	stdev	0.00113404



5.3 - Gain imbalance I/Q



6 - Doppler Analysis

6.1 - Unbiased Doppler Error

Evolution of unbiased Doppler error (Real - Expected)

Ascending

Descending

6.2 - Absolute Doppler

Evolution of Absolute Doppler




Ascending

Descending


6.3 - Doppler evolution versus ANX

Evolution Doppler error versus ANX






rows: _ 3 _ 7 _ 11 _ 15 _ 19 _ 22 _ 24 _ 28




No anomaly detected on visual inspection.

No anomalies observed.






- Stable wave internal calibration pulses gain and phase.
- Stable raw data statistics.
- Nominal Doppler behavior.

Doppler 'WVS' 'IS2' 'H/H'




Doppler 'WVS' 'IS2' 'V/V'






Doppler difference, estimated-predicted 'WVS' 'IS2' 'H/H' -error mean of -30.809619 Hz




Doppler difference, estimated-predicted 'WVS' 'IS2' 'V/V' -error mean of -28.473885 Hz









-100Hz +100Hz

The MS mode provides an internal health check on an individual module basis.
The purpose of this mode is to identify to identify any malfunctioning modules and
to identify modules for which calibration offsets are to be applied.
No anomalies observed on available MS products:

No anomalies observed.







Instrument unavailability from 19-MAR-2003 12:03:47 to 15:00:30

