ERS-2 SAR CYCLIC REPORT

CYCLE 99

05-OCT-2004 to 09-NOV-2004 Orbit 49454 to 49955



Prepared by: Issue: Reference: Date of Issue Status: Document type: Approved by: PCS SAR TEAM 1.0

Technical Note



TABLE OF CONTENTS

INTRODUCTION	3
EXTERNAL CALIBRATION	4
2.1 ERS-2 TRANSPONDER MONITORING	4
ANTENNA PATTERN MONITORING	6
TERNAL CALIBRATION	11
3.1 IMAGE MODE INTERNAL CALIBRATION.	11
3.1.1 High rate products analysis	11
3.1.2 QCP analysis	13
3.2 WAVE MODE INTERNAL CALIBRATION	17
3.2.1 Calibration pulse power monitoring	17
SAR PERFORMANCE	19
4.1 IMAGE/WAVE ACQUISITION	19
4.2 DOPPLER/ATTITUDE ANALYSIS	19
4.2.1 AOCS overview	19
4.2.2 Attitude monitoring	20
4.2.3 SAR high rate Doppler monitoring	21
NNEX A: WAVE CALIBRATION PULSE POWER	24
NNEX B: PRODUCTS OUALITY ANALYSIS	25
	INTRODUCTION



1 INTRODUCTION

This document addresses the results of the analysis made on the ERS-2 SAR instrument for the cycle 99 concerning the following activities:

- 1. external calibration in section 2
- 2. antenna pattern monitoring in section 3.
- 3. internal calibration for High rate and Low bit rate mode in section 0
- 4. attitude/Doppler monitoring in section 4

For further information or comments please write to eohelp@esa.int.



2 EXTERNAL CALIBRATION

External calibration is specific activity performed since the beginning of the ERS-2 mission in order to calibrate the instrument against ground target transponders with a known radar cross-section (RCS).

The SAR calibration site is Flevoland in The Netherlands (NL), with 3 transponders having the following coordinates:

Transponder	Latitude	Longitude
1: Pampushout	+52.36651429N	+5.15197438E
2: Lelystad	+52.45806341N	$+5.52755628^{E}$
3: Minderhout	+52.55502077N	+5.66896505 ^E

Table 1: Flevoland Transponders coordinates

2.1 ERS-2 Transponder monitoring

Please note that transponder 1 was last detected in 2 Feb 1997, and it has been no longer active ever since. Detection of point targets has continued on transponder 2 and 3, with alternating shuts off. Transponder 2 was last visible on 17 Oct 2001, and finally Transponder 3 was last visible on 22 Mar 2002.

From this date, there has been no detection of point targets in the designated areas in all the following NL scenes.

Date	Value	ERSTran2	ERSTran3	Aalsmeer	Edam
	Relative_rcs [dB]	0.551746			
23/06/2000 10:34	Measured_rcs [dB]	58.2417			
	K [dB]	120.603494			
	Relative_rcs [dB]		-0.189056	Ī	
19/07/2000 21:41	Measured_rcs [dB]		57.6609		
	K [dB]		119.121888		
	Relative_rcs [dB]	0.493343	0.170734	Ī	
28/07/2000 10:35	Measured_rcs [dB]	58.1833	58.0207		
	K [dB]	120.486688	119.84147		
01/09/2000 10:35	Relative_rcs [dB]	0.381512	0.165394	Ī	
	Measured_rcs [dB]	58.0715	58.0154		
	K [dB]	120.26302	119.830789		
10/11/2000 10:35	Relative_rcs [dB]	0.381512	-0.503609		



	Measured_rcs [dB]	58.0715	57.3464		
	K [dB]	120.263025	118.492784		
	Relative_rcs [dB]	0.46516	-0.050087		
15/12/2000 10:35	Measured_rcs [dB]	58.1552	57.7999		
	K [dB]	120.430322	119.399827		
	Relative_rcs [dB]		-0.370335		
25/04/2001 21:40	Measured_rcs [dB]		57.4797		
	K [dB]		118.759332		
	Relative_rcs [dB]	0.287502			
04/05/2001 10:34	Measured_rcs [dB]	57.9775			
	K [dB]	120.075006			
	Relative_rcs [dB]			-1.14894	
12/02/2003 10:36	Measured_rcs [dB]			60.2111	
	K [dB]			117.2021	
09/05/2003 10:33	Relative_rcs [dB]				-0.31983
	Measured_rcs [dB]				61.8902
	K [dB]				118.86

With:

relative_rcs[dB] = measured_rcs[dB] - nominal_RCS[dB]

K [dB] = relative_rcs[dB] + K annotated [dB]



3 ANTENNA PATTERN MONITORING

The Amazon Rain-Forest (RF) presents a well-known and very stable backscattering characteristic. Its homogeneity and isotropic properties provide a stable and constant gamma nought allowing the SAR Antenna Pattern monitoring. SAR data are acquired in ascending and descending pass over RF to investigate changes in the antenna pattern. Since transponders are no more available, acquisitions over the RF also support the radiometric stability analysis mainly based on transponders up to now.

The data will be acquired at the station of Cotopaxi (Ecuador) and Cuiaba (Brazil) and shipped to ESRIN/CPRF for processing. The RF data analysis is usually performed each cycle for the previous one due to the time needed to process HR data, causing a delay in the images availability.

Six images have been selected over this area for cycle 98 (30-Aug-2004 / 04-Oct-2004); their characteristics are summarized in Table 2.

Scene	Orbit – Frame	Acquisition date	Centre lat/long (deg)
1	49098 – 7047 (ascending)	10-Sep-2004 03:13:32.696	Lat: -7.009 Lon: 292.554
2	46586 - 7065 (ascending)	10-Sep-2004 03:13:47.760	Lat: -6.115 Lon: 292.355
3	49320 - 3735 (descending)	25-Sep-2004 14:40:09.676	Lat: -6.369 Lon: 293.488
4	49320 - 3753 (descending)	25-Sep-2004 14:40:24.743	Lat: -6.1850 Lon: 292.3670
5	49327 – 7047 (ascending)	26-Sep-2004 03:10:38.020	Lat: -7.05 Lon: 293.4940
6	46815 – 7065 (ascending)	26-Sep-2004 03:10:53.113	Lat: -6.155 Lon: 293.08

 Table 2: Selected Rain Forest scenes for cycle 98

Non-uniform regions have been masked in order to perform the antenna pattern monitoring. Some results of the analysis over the selected scenes are reported in the figures below.

The antenna patterns derived from the selected scenes are shown in Figure 1 and Figure 2; Figure 3, Figure 4 Figure 5 and Figure 6 show the combination of the patterns for the available scenes, and the difference between the current VMP antenna pattern and the patterns combination which is in the range $-0.02 \div 0.08$ dB for ascending passes and $-0.1 \div 0.05$ dB for descending.





Figure 1: Antenna patterns derived from the selected ascending pass plus reference pattern (in black)



Figure 2: Antenna patterns derived from the selected descending passes plus reference pattern (in black)





Figure 3: Antenna pattern combination (red curve) plus reference pattern (black curve) for ascending passes



Figure 4: Difference between the reference pattern and the patterns combination for ascending passes







Figure 5: Antenna pattern combination (red curve) plus reference pattern (black curve) for ascending passes



Figure 6: Difference between the reference pattern and the patterns combination for ascending passes



ERS-2 SAR Cyclic Report Cycle 99

Due to a wrong command uploaded on board a significant decrease (4dB) of the replication pulse power occurred during the current cycle; this power drop affected the instrument calibration and all data acquired from 04-SEP-2004 10:04:14 to 14-OCT-2004 14:37:11 UTC. The scenes available over Rain Forest were acquired in this time range so the absolute calibration check, usually performed referring the mean gamma value, is not performed here.



INTERNAL CALIBRATION

3.1 Image mode internal calibration

During the cycle 82, a gain increase of 3.5dB has been performed in two steps:

- Increase of the Image up-converter level by 2.5dB on 26 February 2003.
- Decrease of the Image receiver attenuation gain by 1dB on 28 February 2003.

During the cycle 98, an erroneous command uploaded on board causes a significant decrease 4dB of the replication pulse power. Images acquired from 04-SEP-2004 10:04:14 to 14-OCT-2004 14:37:11 UTC are affect by this power drop. Since this drop affects only the instrument calibration, it can be corrected afterwards using the good replica power as given in the section below.

3.1.1 High rate products analysis

3.1.1.1 Replica pulse power monitoring

The replica pulse power is extracted from the annotations of the level 1 High Rate SLC and PRI products. As shown in the following plot, the replica pulse power has lost ~5dB since the beginning of the mission with a regular slope of -0.57 dB/year until the gain increase of 3.5B performed in February 2003. Figure 7 shows that the calibration pulse power has retrieved the level of May 1998. Since the gain increase, the replica pulse power is decreasing with a slope of -0.172dB/Cycle.

Figure 8 shows the evolution of the HR calibration pulses during the current cycle. On cycle 98, the calibration pulse power drops by 4dB from 50.16dB to 45.799dB. After correction, the power level went back on cycle 99 to a nominal value of 49.911dB.





Figure 7: Evolution of Replica pulse power for High Rate products



Figure 8: Evolution of replica pulse power for cycle 98 and 99



Year	Jan-Feb-Mar	Apr-May-Jun	Jul-Aug-Sep	Oct-Nov-Dec
1995	Not available	Not available	215.23	210.835
1996	203.534	201.705	196.501	184.085
1997	178.818	173.012	164.666	159.916
1998	155.797	150.462	146.509	140.186
1999	139.446	133.889	132.352	129.449
2000	127.202	121.463	120.669	115.158
2001	110.416	109.128	99.859	98.068
2002	91.014	93.22	86.05	82.954
2003	76.578 /151.28	153.464	153.805	148.575
2004	146.281	149.892	147.715/77.274	141.86

Table 3 gives the replica pulse power correction factor averaged over 3 months.

 Table 3: Evolution of the Replica Pulse Power correction factor from the HR products. The yellow case is relative to the gain increase of March 2003 and to the power drop of September 2004.

3.1.2 QCP analysis

As a replacement of the $UIND^1$ and UIC^2 products, the QCP files are used to monitor the evolution of the:

- replica pulse power,
- calibration pulse power and
- noise power (not calibrated)

In particular, QCP gives two measures of the above parameters: at the start/end of the acquisition. For further details on QCP, please see annex B. Please see Figure 9 for trend plots where red points are for the measures at the beginning of the product and green are the ones at the end.

Replica Pulse Power

The replica pulse power measurements (start/stop) are almost identical. Since the gain increase, the level decreases with a slope –0.54dB/year. Due to the anomaly of cycle 98, the power level drops from 49.29dB to 45.12dB. After correction, the power level went back on cycle 99 to a nominal value of 49.04dB as shown in Figure 10. As done previously with the HR products, the mean replica pulse power derived from the QCP is given in Table 4.

2. Calibration Pulse Power

As the measure made at the end of the segment is noisier, only the first measure is used. For the current cycle the power level has reached a mean level of 43.52dB. As shown in Figure 11 there is (as expected) a linear correlation between replica and calibration pulse power. However, the effect of the power drop is clearly visible as it appears like outliers to this linear

¹ UIND gives information on noise power level and the calibration pulse power level

² UIC gives on the replica Pulse power



relationship. Since the gain increase, the mean calibration pulse power is decreasing with a regular slope of -0.44dB/year.

3. Noise Power

The noise power level seems to be constant during the whole mission. It decreases with a low slope of -0.04dB/year from the last gain increase. During the current cycle it has reached a mean level of 7.18dB.

Year	Jan-Feb-Mar	Apr-May-Jun	Jul-Aug-Sep	Oct-Nov-Dec
1996	211.622	205.018	Not available	184.384
1997	182.15	173.055	167.219	162.305
1998	155.998	151.48	144.595	138.553
1999	135.867	128.822	Not available	127.188
2000	115.325	109.939	109.38	105.205
2001	101.302	97.039	91.881	88.518
2002	83.486	81.575	77.354	72.151
2003	70.864/145.35	139.799	134.951	129.152
2004	122.444	123.601	121.708/ 47.42	113.467

 Table 4: Evolution of Replica Pulse correction factor for QCP files. The yellow case is relative to the gain increase of March 2003 and to the power drop of September 2004.





Figure 9: Evolution of Replica, calibration and noise pulses from QCP files. Red points are for the measures at the beginning of the product, while green are the ones at the end.





Figure 10: Evolution of Replica, calibration and noise pulses from QCP files for the cycle 99.



Figure 11: Joint evolution of Replica and calibration pulses. Black dots represent all the data. Red ones are the data since cycle 98.



3.2 Wave mode internal calibration

3.2.1 Calibration pulse power monitoring

From cycle 39 to 77 (Jan-1999 to Sep-2002), the calibration pulse power was decreasing with a slope of -0.215dB/year.

On 4th September 2002 an update of the ERS-2 AMI up-converter gain occurred. For wave mode the gain was increased by 3dB. However, only a change of ~1dB has been measured, as shown in Figure 12. The level of the calibration pulse power rose up from 23.5dB to 24.4dB. Since the gain increase, the power level is decreasing with a regular slope of -0.22dB/year.

The calibration pulse power has reached for the current cycle a mean level of 23.92dB as show in Figure 13.





Figure 12: Evolution of Mean Calibration Pulse



Figure 13: Evolution of Calibration Pulse Power for the current cycle

Please see appendix A for further details on calibration pulse power.



4 SAR PERFORMANCE

4.1 Image/Wave acquisition

Starting from July 2003, due to tape recorders failure, the ERS LR mission continues within the full coverage of ESA LBR receiving stations, which are:

- Maspalomas, Gatineau, Prince Albert, Kiruna: immediately available
- West Freugh, Matera, O'Higgins: available in the near future

Please note that SAR HR mission is not affected. By consequence, SAR image availability is not influenced.

4.2 Doppler/Attitude analysis

4.2.1 AOCS overview

ERS-2 was piloted in yaw-steering mode using three gyroscopes since the beginning of the mission until February 2000, when a new yaw-steering mode using only one gyroscope was implemented. The ERS-2 gyroscopes have experienced several problems during the mission and the new monogyro mode (1GP) was intended to ensure the mission continuity even in case of additional failures. In January 2001 a new test piloting mode using no gyroscopes, the Extra-Backup Mode (EBM), was implemented as a first stage of a gyro-less piloting mode. The aim of this challenging mode was to maintain the remaining gyroscopes performance only for those activities absolutely requiring them, such as some orbit manoeuvres. A more accurate version of this yaw-steering zerogyro mode (ZGM) was operationally used since June 2001 and the performance was further improved with the implementation of the Yaw Control Monitoring mode (YCM) at the beginning of 2002. The evolution from the nominal and extremely stable three-gyro piloting mode (3GP) to the YCM has allowed to successfully continuing the ERS-2 operations despite of the gyroscopes failures. Nevertheless, this evolution has significantly affected the stability of the satellite attitude and the SAR Doppler Centroid frequency. Figure 14 gives a summary of the ERS-2 piloting modes.



Figure 14: Summary of ERS-2 Piloting Mode



As an example of the attitude instability Figure 15 shows the evolution of the Doppler Centroid since the beginning of the ERS-2 mission.



Figure 15: Evolution of Doppler Centroid Frequency since the beginning of the mission

4.2.2 Attitude monitoring

The YCM piloting mode requires a monitoring in near real time of the yaw angle. The mean yaw per orbit angle is currently derived HEY (scatt) products.



Figure 16: Mean yaw angle/orbit derived from HEY data since 06-JUN-2004

The mean yaw per orbit is most of the time constrain between $\pm 2 \text{ deg}$. For the current cycle the yaw angle has a bias of -0.05deg with a deviation 0.878deg.



4.2.3 SAR high rate Doppler monitoring

For monitoring purposes a specific HR product ordering (~90 products per cycle) is made to follow the evolution of the platform attitude/Doppler Centroid frequency.

For the current cycle 100% of the analyzed products have a Doppler centroid within ± 4500 Hz. However the dispersion over a same orbit position is representative of an attitude instability relative to a very high yaw variation, as shown in Figure 17.









Figure 17: SAR HR Doppler Centroid evolution in time for versus seconds from ANX and in time.



ANNEX A: WAVE CALIBRATION PULSE POWER

Noise power density, scaled and unscaled calibration pulse power can be calculated extracting the following parameters from **UWAND** products:

- σ_I the standard deviation of I part noise data on SPH
- σ_Q the standard deviation of Q part noise data on SPH
- I and Q part of the 4 calibration pulse datasets

Noise power density

The noise power density is defined as follows:

 $npd = \sigma_i^2 + \sigma_q^2$

Calibration pulse power

For each four DSRs, we search the peak intensity of the calibration pulses. In order to take into account only the energy of the main lobe of the calibration pulses only 16 samples are used around the peak. If p is the position of the peak the calibration pulse power for one DSR is defined as following:

$$powerDSR = \frac{1}{16} \sum_{n=p-8}^{p+7} I_n^2 + Q_n^2$$

The Calibration Pulse Power is obtained by averaging:

CalibrationPulsePower =
$$\frac{1}{4}\sum_{j=1}^{4} powerDSR(j)$$

a) Unscaled calibration pulse power The unscaled calibration power is identical as the previous formula:

$$UnscaledCalibrationPulsePower = CalibrationPulsePower = \frac{1}{4}\sum_{j=1}^{4}powerDSR(j)$$

b) Scaled calibration pulse power The scaled calibration pulse power is defined as follows:

 $scaledCalibrationPulsePower = CalibrationPulsePower - 16*npd = \left[\frac{1}{4}\sum_{j=1}^{4}powerDSR(j)\right] - 16*npd$



ANNEX B: PRODUCTS QUALITY ANALYSIS

This activity is principally dedicated to the user support. The two main types of activities are:

- Verification of products with a high Doppler value (rejected products)
- Product quality/format anomalies

Rejected products during the cycle

Rejected products are those having Doppler Centroid frequencies outside the interval [-4500,4500] Hz. In this case VMP ambiguity estimation is not reliable so the product's focusing has to be checked.

Product quality anomalies

Products quality anomalies are detected internally or via the users complaints. The action is to analyze the faulty products and report the analysis results.



Annex C: Example of QCP file

Processing - ERS_2_\$QCP200_027387.\$EXCHANGE
Filename = ERS_2_\$OCP200_027387 \$EXCHANGE
File size in bytes $= 3551$
Time of last access $= 01$ -NOV-2002 19:33:37 000
Time of last data modification $= 27$ -IUL -2000 09:38:23 000
Time of last data incurrentiation $= 27.502 2000 09:38:23.000$
27 001 2000 07.50.25.000
[OCP200Header]
Filename = ERS_2_\$QCP200_027387.\$EXCHANGE
ArrivalTime = $2000-07-2709:38:23$
Platform Id $= 2$
NumOfPasses = 1
PassId = 1
NumOfImagingSeqs = 1
[ImageSeqId_1]
NumberOfValidNoisePulsesStart $= 3$
Number Of Valid Calib Pulses Start $= 4$
NumberOfValidRepPulsesStart = 8
MeanPowerOfValidRepStart = 78166.750000
MeanPowerOfValidRepFlagStart = 0.000000
IndexOfFirstValidRepSampleWindowStart = 29
First ValidReplicaSampleWindowFlagStart = 1
RangeCompressionNormFactorStart = 77990.000000
KangeCompressionNormFactorFlagStart = 0
MeanPowerOf ValidCalibStart = 18861.839990
MeanPowerOf ValidCalibFlagStart = 0
MeanPowerOIV alidNoiseStart = 5.681800
MeanPowerUI ValidNoiseFlagStart = 1
Number Of ValidNoisePulsesEnd $= 6$
NumberOf ValidCalibPulsesEnd = 4
NumberOI v and kep Pulses End $= \delta$ Maar Demar Of Valid Denlies End $77005, 250000$
MeanPowerOI v and KephicaEnd = 77995.250000 MeanPowerOf Valid PenliceElegEnd = 0
IntealirOwerOf ValidReplicaFlagEliu = 0 IndexOfFiretValidDeplicaFlagEliu = 0
First Valid Danliga Somnlo Window Elac End 1
Pirst v and Replica Sample w indow Plagend = 1 $Pange Compression Norm Faster End = -77800,0000000$
RangeComplessionNormEactorElacEnd = 7/890.000000
KangeComplexionNonnractorragend = 0 $MageDomodeValidCalibEnd = 18015,227250$
MeanPowerOfValidCalibElagEnd = 0
$\frac{1}{10000000000000000000000000000000000$
Mean Dower Of Valid Noise Elac = 1
MeanPonlicePulsePowerUnnerThreehold = 255000 000000
MeanReplicaPulsePowerLowerThreshold = 255000.000000
MeanNoiseSignalDowerUnnerThreshold – 7 50000
MeanNoiseSignalPowerLowerThreshold -2.500000
Mean Calib Signal Power Upper Threshold $= 2.500000$
MeanCalibSignalDowerLowerThreshold = -3750,000000
RangeCompressNormEactorUpperThreshold = 255000 000000
RangeCompressNormEactorLowerThreshold = 255000.000000
Rangeeonpressionini actorizower fillesnolu – 65000.000000