
Summary of Anomalies:

Station Info

EGOI OK

Instrument Info

1 - Memory Dump (change to the day before):

Address 1389E in E2PROMCOPY changed from template value E0 to actual A0
(first occurrence of a change in this address)

GOME Daily Reports Analysis 11 JUN 2002

Station ID	OK
MPH Product Confidence	OK
SPH Window Information	OK
Command Word Echo Summary	OK
Instrument Status 1A	OK
Instrument Status 1B	OK
Instrument Status 2	OK
Integration Times Channel 1	OK
Co-Adding and Cluster Mode Flags	OK
Integration Times Band 2A	OK
Integration Times Band 2B	OK
Integration Times Band 3	OK
Integration Times Band 4	OK
Scan Mirror Position	OK
Polarisation Detectors	OK
FPA Temperatures A	OK
FPA Temperatures B	OK
Charge Amp Temperatures	OK
Other Temperatures A	OK
DDHU Temperatures	OK
Optical Bench Temperatures	OK
Other Temperatures B	OK
Calibr. Lamp and Instr. Status 3	>> Solar calibration performed in dump Orb. 37337 start of sun calibration 10:47:52 intensity of sun calibration: ~ 16460 BU ->PMD2 readouts analysed with ERGO; (note: due to seasonal effects nominal values range between ~16000 - ~19000 BU
Scan Mirror Motor Current	OK
Selected Temperature A	OK
Selected Temperature B	OK
Selected Temperature C	OK
Channel 1 Summation	OK
Channel 2 Summation	OK
Channel 4 Summation	OK
Log pages	OK
331/318 nm Uncal. Line Ratio	OK
Uncal. PMDs as RGB signal	OK
780 nm Uncal. Intensity	OK

GOME Memory Dump Check 11 JUN 2002

GOME Daily Dump Check of processing day 020611

8907 differences found in RAM1 area
0 differences found in PROMCOPY area
7 differences found in E2PROMCOPY area

Address	Actual	Template
12FDE	0	FF
12FDF	7	FF
13003	0	1
13007	0	1
1300B	1	10
1389E	A0	E0
17FFF	FD	FF

0 differences found in E2PROM area
0 differences found in RAM2 area
0 differences found in PROM area