
Summary of Anomalies:

Update
station info
OK

instrument info
EGOI OK

GOME Daily Reports Analysis 19 Mar 2003

Station ID	OK	
MPH Product Confidence	OK	
SPH Window Information	OK	
Command Word Echo Summary	OK	
Instrument Status 1A	OK	
Instrument Status 1B	OK	
Instrument Status 2	OK	
Integration Times Channel 1	OK	
Co-Adding and Cluster Mode Flags	OK	
Integration Times Band 2A	OK	
Integration Times Band 2B	OK	
Integration Times Band 3	OK	
Integration Times Band 4	OK	
Scan Mirror Position		-GOME polar viewline GMNPT35 operated
Polarisation Detectors	OK	
FPA Temperatures A	OK	
FPA Temperatures B	OK	
Charge Amp Temperatures	OK	
Other Temperatures A	OK	
DDHU Temperatures	OK	
Optical Bench Temperatures	OK	
Other Temperatures B	OK	
Calibr. Lamp and Instr. Status 3	>>	Solar calibration performed in dump Orb. 41359 start of sun calibration 10:22:53.03 intensity of sun calibration: ~17100 BU ->PMD2 readouts analysed with ERGO; (note: due to seasonal effects nominal values range between ~16000 - ~19000 BU)
Scan Mirror Motor Current	OK	
Selected Temperature A	OK	
Selected Temperature B	OK	
Selected Temperature C	OK	
Channel 1 Summation	OK	
Channel 2 Summation	OK	
Channel 4 Summation	OK	
Log pages	OK	
331/318 nm Uncal. Line Ratio	OK	
Uncal. PMDs as RGB signal	OK	
780 nm Uncal. Intensity	OK	

GOME Memory Dump Check 19 Mar 2003

8872 differences found in RAM1 area
0 differences found in PROMCOPY area
6 differences found in E2PROMCOPY area

Address	Actual	Template
12FDE	0	FF
12FDF	7	FF
13003	0	1

```
13007      0      1
16CD9     2D     25
17FFF     FD     FF
0 differences found in E2PROM area
0 differences found in RAM2 area
0 differences found in PROM area
```