




1 General Comments

The activities scheduled for this week are those planned for the CW06.



This week is scheduled.

- PMS Offset Calibrations scheduled on 07/02/2012
- X-Band Passes over ESAC and Svalbard.
- Gyro Calibration performed on 05/02/13. This platform activity lasts around 1 orbit, and implied SMOS to point away from the canonical attitude. From 13:11:55z to 14:52:54 the data will be flagged as External. The pass scheduled at 14:17z over SVAL was not transmitted from the instrument.

2 Mission Planning Deviation

None



3 TC Failures

None.

4 Unforseen Out Of Limits (OOLs)

See appendix A for a complete list of OOL's in the period.

5 On Board Anomalies

None

6 Telemetry On Board Events in the period.

Event Description	Severity	Event Time	Parameters
RAM single Bit Error	Warn	2013.035.22.53.49.680	20E0F00
RAM single Bit Error	Warn	2013.037.07.13.52.992	221D84C

7 FOS System Status

None

8 Data Reception from CNES

Delays in the reception of the pair of PILVR files, since 21/01/2013 the second file of the two PILVR files is arriving 20 seconds later than the first one, before it arrived with 2 seconds of difference. This behaviour implies that the polling daemon believes that the second file is missing and it does not work properly and finally moves the set of two PILVR files to failed directory. The PTME_WAIT_TIMEOUT value has changed to 120 seconds and E-HKTM-Gateway restarted but the problem persists.

9 X-Band Data Reception in PXMF

No events on board in the period were causing loss of sensed data.



10 Exceptional Activities

None

11 AOB

None.



APPENDIX A: OOL's

Event Logger printout from time: 2013.035.00.00.00.002 to time: 2013.042.00.00.00.010

Current printout time: 2013.043.14.09.28.366

Filter info:

Application : All
Workstation : All
Packets type : All
Packets severity : All
Message filter :

Event time	Stream	Application	Workstation	Severity	Type	Message
2013.036.13.47.28.114	1	BEHVlimitChecker	plpcprm	ERROR	LOG	2013.036.13.11.47.298 NTLHK022
VAL: Disabled STATE: Enabled STATUS limit is out of nominal range						